



Alpha Analytical Laboratories Inc.

e-mail: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

ELAP Certificates 1551, 2728, and 2922

06 March 2017

Environmental.Com

Attn: David Pingatore

6398 Dougherty Road, Suite 36

Dublin, CA 94568

RE: Fremont Unified School District

Work Order: 17B1980

Enclosed are the results of analyses for samples received by the laboratory on 02/21/17 21:50. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Jeanette L. Poplin For David S. Pingatore

Project Manager



# alpha

Alpha Analytical Laboratories Inc.

e-mail: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Environmental.Com  
6398 Dougherty Road, Suite 36  
Dublin, CA 94568

Project Manager: David Pingatore  
Project: Fremont Unified School District  
Project Number: Forest Park Elementary

Reported:  
03/06/17 11:20

## ANALYTICAL REPORT FOR SAMPLES

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
Lobby	17B1980-01	Water	02/17/17 05:58	02/21/17 21:50
Kitchen	17B1980-02	Water	02/17/17 06:02	02/21/17 21:50
Classroom 507	17B1980-03	Water	02/17/17 06:05	02/21/17 21:50
Classroom 205	17B1980-04	Water	02/17/17 06:10	02/21/17 21:50
Classroom 307	17B1980-05	Water	02/17/17 06:15	02/21/17 21:50



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Environmental.Com  
6398 Dougherty Road, Suite 36  
Dublin, CA 94568

Project Manager: David Pingatore  
Project: Fremont Unified School District  
Project Number: Forest Park Elementary

Reported:  
03/06/17 11:20

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note
<b>Lobby (17B1980-01)</b>		<b>Sample Type: Water</b>			<b>Sampled: 02/17/17 05:58</b>			
<b>Metals by EPA Method 200.8 ICP/MS</b>								
Copper	ND ug/L	40	1	AB74038	02/27/17 08:51	02/27/17 20:21	EPA 200.8	
Lead	ND ug/L	4.0	1	AB74038	02/27/17 08:51	02/27/17 20:21	EPA 200.8	
<b>Kitchen (17B1980-02)</b>		<b>Sample Type: Water</b>			<b>Sampled: 02/17/17 06:02</b>			
<b>Metals by EPA Method 200.8 ICP/MS</b>								
Copper	71 ug/L	40	1	AB74038	02/27/17 08:51	02/27/17 20:26	EPA 200.8	
Lead	ND ug/L	4.0	1	AB74038	02/27/17 08:51	02/27/17 20:26	EPA 200.8	
<b>Classroom 507 (17B1980-03)</b>		<b>Sample Type: Water</b>			<b>Sampled: 02/17/17 06:05</b>			
<b>Metals by EPA Method 200.8 ICP/MS</b>								
Copper	390 ug/L	40	1	AB74038	02/27/17 08:51	02/27/17 20:32	EPA 200.8	
Lead	ND ug/L	4.0	1	AB74038	02/27/17 08:51	02/27/17 20:32	EPA 200.8	
<b>Classroom 205 (17B1980-04)</b>		<b>Sample Type: Water</b>			<b>Sampled: 02/17/17 06:10</b>			
<b>Metals by EPA Method 200.8 ICP/MS</b>								
Copper	120 ug/L	40	1	AB74038	02/27/17 08:51	02/27/17 20:37	EPA 200.8	
Lead	ND ug/L	4.0	1	AB74038	02/27/17 08:51	02/27/17 20:37	EPA 200.8	
<b>Classroom 307 (17B1980-05)</b>		<b>Sample Type: Water</b>			<b>Sampled: 02/17/17 06:15</b>			
<b>Metals by EPA Method 200.8 ICP/MS</b>								
Copper	390 ug/L	40	1	AB74038	02/27/17 08:51	02/27/17 18:23	EPA 200.8	
Lead	ND ug/L	4.0	1	AB74038	02/27/17 08:51	02/27/17 18:23	EPA 200.8	



alpha

Alpha Analytical Laboratories Inc.

e-mail: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Environmental.Com

6398 Dougherty Road, Suite 36

Dublin, CA 94568

Project Manager: David Pingatore

Project: Fremont Unified School District

Project Number: Forest Park Elementary

Reported:

03/06/17 11:20

#### Notes and Definitions

ND Analyte NOT DETECTED at or above the reporting limit

dry Sample results reported on a dry weight basis

RPD Relative Percent Difference

**Corporate Laboratory**  
208 Mason Street, Ukiah CA 95482  
707-468-0401 F) 707-468-5267  
email: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)

Reports and Invoices delivered by email in PDF format

17B1980 Pg. of

9090 Union Park Way #113, Elk Grove CA 95624  
916-686-5190 F\ 916-686-5192

**ELAP Certifications**  
 Ukiah 1551 / Dublin 2728 / Elk Grove 2922

## WATER, SEDIMENTS, SOLIDS

[illegible]