

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267 Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309 Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

ELAP Certificates 1551, 2728, and 2922

01 March 2017

Environmental.Com

Attn: David Pingatore

6398 Dougherty Road, Suite 36

Dublin, CA 94568

RE: Fremont Unified School District

Work Order: 17B1497

Enclosed are the results of analyses for samples received by the laboratory on 02/14/17 21:10. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Jeanette L. Poplin For David S. Pingatore

Jeanette Popli

Project Manager



## Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267
Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309
Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Environmental.Com

Dublin, CA 94568

Project Manager: David Pingatore

6398 Dougherty Road, Suite 36

Project: Fremont Unified School District Project Number: Warm Springs Elementary Reported: 03/01/17 10:36

## ANALYTICAL REPORT FOR SAMPLES

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
Kitchen	17B1497-01	Water	02/14/17 05:47	02/14/17 21:10
Room 7	17B1497-02	Water	02/14/17 05:52	02/14/17 21:10
Outside Drinking Fountain	17B1497-03	Water	02/14/17 05:54	02/14/17 21:10
Room 18	17B1497-04	Water	02/14/17 05:57	02/14/17 21:10
Room 35	17B1497-05	Water	02/14/17 06:01	02/14/17 21:10



## Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267
Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309
Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Environmental.Com Project Manager: David Pingatore
6398 Dougherty Road, Suite 36 Project: Fremont Unified School District

6398 Dougherty Road, Suite 36 Project: Fremont Unified School District Reported:

Dublin, CA 94568 Project Number: Warm Springs Elementary 03/01/17 10:36

Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note
	Sample Type: Water			Sampled: 02/14/17 05:47			
ND ug/L	40	1	AB73695	02/17/17 10:33	02/17/17 16:58	EPA 200.8	
ND ug/L	4.0	1	AB73695	02/17/17 10:33	02/17/17 16:58	EPA 200.8	
	Sample Type: Water		Sampled: 02/14/17 05:52				
120 ug/L	40	1	AB73695	02/17/17 10:33	02/17/17 17:02	EPA 200.8	
ND ug/L	4.0	1	AB73695	02/17/17 10:33	02/17/17 17:02	EPA 200.8	
	Sample Type: Water			Sample	d: 02/14/17 05:54		
120 ug/L	40	1	AB73695	02/17/17 10:33	02/17/17 17:06	EPA 200.8	
ND ug/L	4.0	1	AB73695	02/17/17 10:33	02/17/17 17:06	EPA 200.8	
	Sample Type: Water		Sampled: 02/14/17 05:57				
ND ug/L	40	1	AB73695	02/17/17 10:33	02/17/17 17:11	EPA 200.8	
ND ug/L	4.0	1	AB73695	02/17/17 10:33	02/17/17 17:11	EPA 200.8	
	Sample Type: Water			Sampled: 02/14/17 06:01			
98 ug/L	40	1	AB73695	02/17/17 10:33	02/17/17 17:15	EPA 200.8	
ND ug/L	4.0	1	AB73695	02/17/17 10:33	02/17/17 17:15	EPA 200.8	
	ND ug/L ND ug/L 120 ug/L ND ug/L ND ug/L ND ug/L ND ug/L ND ug/L ND ug/L	ND ug/L   40   ND ug/L   40   Sample Type:	ND ug/L   40   1   ND ug/L   4.0   1   Sample Type: Water	ND ug/L	Sample Type: Water	Sample Type: Water   Sampled: 02/14/17 05:47	ND ug/L   40   1   AB73695   02/17/17 10:33   02/17/17 16:58   EPA 200.8



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267
Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309
Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Environmental.Com Project Manager: David Pingatore

6398 Dougherty Road, Suite 36 Project: Fremont Unified School District Reported:

Dublin, CA 94568 Project Number: Warm Springs Elementary 03/01/17 10:36

## **Notes and Definitions**

ND Analyte NOT DETECTED at or above the reporting limit

dry Sample results reported on a dry weight basis

RPD Relative Percent Difference

Multical Laboratories Inc. WATERS, SEDIMENTS, SOLIDS www.alpha-labs.com

hone/Fax:

email: clientservices@alpha-labs.com **Corporate Laboratory** 208 Mason Street, Ukiah CA 95482 707-468-0401 F) 707-468-5267

Central Valley Laboratory 9090 Union Park Way #113, Elk Grove CA 95624 916-686-5190 F) 916-686-5192 ELAP Certifications Ukiah 1551 / Dublin 2728 / Elk Grove 2922

Bay Area Laboratory 6398 Dougherty Rd #35, Dublin CA 94568 925-828-6226 F) 925-828-6309

Reports and Invoices delivered by email in PDF format 1781497 Lab No

Chain of Custody - Work Order

FIELD TECH DEPARTURE TIME: <u>2</u> Elk Grove temp: ž Temp upon Receipt °C If "Y" please enter the Source Number(s) in the column above Dublin temp: FIELD TECH ARRIVAL TIME: Ukiah temp: **DDW Source Numbers:** V, Sample Notes or Signature below authorizes work under terms stated on reverse side. 0150 0003 Sampling Company Log Code 0 Lab preapproval required 10 days Standard days TAT DDW Write On EDT Transmission? CA Geotracker EDF Report? State System Number: EDF to (Email Address): Travel and Site Time: **Analysis Request** Global ID: 1720 715 Time qidest × Cn DW 200.8 ICPMS Pb DW 200.8 ICP/MS 2114 Date Total Number of Containers per Sample ID adi₩ Matrix lioS Project Information × × × × Fremont Unified × Water Warm Springs School District Elementary Hone Other PO Number: Project No: H2SO4 Project ID: × × × × HNO3 Received by HCI Other Sleeve Class Invoice to (if different) × × × × Poly lsiV lm04 10% 0% 0554 0557 (J. J.) Time BB Sampling mail address: 41-6 Date *bl-C* カル 714 Phone/Fax: H-6 Jetos Sanchez Outside drinking Southing Field Sampler - Printed Name & Signature: Sample Identification Relinquished by 200m 18 Siteries Report to david@environmental.com 500m 2002 Environmental.com David Pingatore mail Address

03) 8 05)